
APOLLO bassano vertical technical specification



NICIONIC							
INDICING	(mm)	BASSANO VERTICAL SINGLE DIMENSIONS (mm)					
	1800						
	304	464	624				
	8	12	16				
	45 x 20						
	No. of tubes x 40 - 16						
(A)		118					
	N/A						
(B)	54						
		N/A					
(C)	240	400	560				
(Dt)		17.5					
(Db)		0					
		1/2"					
	(A) (B) (C) (Dt)	304 8 No. o (A) (B) (C) 240 (Dt)	(A) 1800 304 464 8 12 45 x 20 No. of tubes x 44 (A) 118 N/A (B) 54 N/A (C) 240 400 (Dt) 17.5 (Db) 0				

BASSANO VERTICAL DOUBLE DIMENSIONS (mm)					
MODEL HEIGHT			1800		
Width of radiator			304	464	624
No. of tubes			8 (x2)	12 (x2)	16 (x2)
Section depth x width			45 x 20		
Nominal width			No. of tubes x 40 - 16		
Back wall to front of rad		(A)	166		
Back wall to pipe centres	Side entry		N/A		
Back wall to pipe certifies	Bottom entry	(B)	103		
Tapping centres	Side entry			N/A	
rapping centres	Bottom entry	(C)	240	400	560
Bracket positions	Тор	(Dt)		17.5	
Bracket positions	Bottom	(Db)	0		
Tappings				1/2"	

rappings	-/-			
ADDITIONAL INFORMATION				
Material	Steel			
Alloy thickness	1.2mm			
Maximum working pressure	4 bar/400 kPa			
Mechanical strength test pressure	7 bar/700 kPa			
Maximum working temperature	110°C			

NB: The 304 wide has side <u>and</u> bottom tappings Side tappings are for manufacturing purposes only and CANNOT be used Use BOTTOM ENTRY tappings only Fitting instructions are provided and should be followed

BASSANO VERTICAL SINGLE WEIGHTS & VOLUMES (per radiator)				
Model width (mm)	304	464	624	
Dry weight (A) Kg	23.20	34.80	46.40	
Water content (B) Litres	10.64	15.96	21.28	
Working weight (A+B) Kg	33.84	50.76	67.68	
Outputs: Watts ΔT=50k	859	1289	1719	
The thermal outputs expressed at ΔT=50k comply with European regulation EN 442-2				

BASSANO VERTICAL DOUBLE WEIGHTS AND VOLUMES (per radiator)					
Model width (mm)	304	464	624		
Dry weight (A) Kg	45.12	67.68	90.24		
Water content (B) Litres	20.64	30.96	41.28		
Working weight (A+B) Kg	65.76	98.64	131.52		
Outputs: Watts ΔT=50k 1379 2068 2758					
The thermal outputs expressed at ΔT =50k comply with European regulation EN 442-2					

TEMPERATURE				
FACTORS FOR DIFFERENCES BETWEEN MEAN				
WATER TEMPERATURE AND ROOM				
TEMPERATURE IN °C AND °F OTHER THAN				
50°C (90°F)				
5°C	0.050			
10°C	0.123	10°F	0.057	
15°C	0.209	20°F	0.142	

5°C	0.050		
10°C	0.123	10°F	0.057
15°C	0.209	20°F	0.142
20°C	0.304	30°F	0.240
25°C	0.406	40°F	0.348
30°C	0.515	50°F	0.466
35°C	0.629	60°F	0.590
40°C	0.748	70°F	0.721
45°C	0.872	80°F	0.858
50°C	1.000	90°F	1.000
55°C	1.132	100°F	1.147
60°C	1.267	110°F	1.298
65°C	1.406	120°F	1.454
70°C	1.549	130°F	1.613
75°C	1.694	140°F	1.776

TO APPLY THE FACTORS SHOWN IN THE TABLE
TO OUR QUOTED OUTPUTS.
MULTIPLY THE QUOTED OUTPUT BY THE
CHOSEN OPERATING FACTOR TO GIVE THE

OUTPUT